

PROPERTY TRANSFER NOTIFICATION CERTIFICATION

This form is to be signed by the prospective purchaser before signing a purchase and sale agreement or a memorandum of agreement, or by the lessee-prospective purchaser before signing a lease with an option to purchase for residential property built before 1978, for compliance with federal and Massachusetts lead-based paint disclosure requirements.

Required Federal Lead Warning Statement:

Every purchaser of any interest in residential property on which a residential dwelling was built prior to 1978 is notified that such property may present exposure to lead from lead-based paint that may place young children at risk of developing lead poisoning. Lead poisoning in young children may produce permanent neurological damage, including learning disabilities, reduced intelligence quotient, behavioral problems and impaired memory. Lead poisoning also poses a particular risk to pregnant women. The seller of any interest in residential real property is required to provide the buyer with any information on lead-based paint hazards from risk assessments or inspections in the seller's possession and notify the buyer of any known lead-based paint hazards. A risk assessment or inspection for possible lead-based paint hazards is recommended prior to purchase.

Seller's Disclosure

(a) Presence of lead-based paint and/or lead-based paint hazards (check (i) or (ii) below):

(i) Known lead-based paint and/or lead-based paint hazards are present in the housing (explain).

(ii) Seller has no knowledge of lead-based paint and/or lead-based paint hazards in the housing.

(b) Records and reports available to the seller (check (i) or (ii) below):

(i) Seller has provided the purchaser with all available records and reports pertaining to lead-based paint and/or lead-based paint hazards in the housing (circle documents below).

Lead Inspection Report; Risk Assessment Report; Letter of Interim Control; Letter of Compliance

(ii) Seller has no reports or records pertaining to lead-based paint and/or lead-based paint hazards in the housing.

Purchaser's or Lessee Purchaser's Acknowledgment (initial)

(c) Purchaser or lessee purchaser has received copies of all documents circled above.

(d) Purchaser or lessee purchaser has received no documents.

(e) Purchaser or lessee purchaser has received the Property Transfer Lead Paint Notification.

(f) Purchaser or lessee purchaser has (check (i) or (ii) below):

(i) received a 10-day opportunity (or mutually agreed upon period) to conduct a risk assessment or inspection for the presence of lead-based paint and/or lead-based paint hazards; or

(ii) waived the opportunity to conduct a risk assessment or inspection for the presence of lead-based paint and/or lead-based paint hazards.

Agent's Acknowledgment (initial)

(g) Agent has informed the seller of the seller's obligations under federal and state law for lead-based paint disclosure and notification, and is aware of his/her responsibility to ensure compliance.

(h) Agent has verbally informed purchaser or lessee-purchaser of the possible presence of dangerous levels of lead in paint, plaster, putty or other structural materials and his or her obligation to bring a property into compliance with the Massachusetts Lead Law — either through full deleading or interim control — if it was built before 1978 and a child under six years old resides or will reside in the property.

Certification of Accuracy

The following parties have reviewed the information above and certify, to the best of their knowledge, that the information they have provided is true and accurate.

Andrew H. Giff 8/24/15
Seller Date

[Signature] 8/25/15
Seller Date

Purchaser Date

Purchaser Date

[Signature]
Agent Date

Agent Date

Property Address: 423 Concord Rd, Weston, MA 02493




Commonwealth of Massachusetts
Title 5 Official Inspection Form
 Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

Owner information is required for every page.

423 Concord Rd
 Property Address
 Audrey Yett
 Owner's Name
 Weston Ma 02493 6/11/14
 City/Town State Zip Code Date of Inspection

Inspection results must be submitted on this form. Inspection forms may not be altered in any way. Please see completeness checklist at the end of the form.

Important: When filling out forms on the computer, use only the tab key to move your cursor - do not use the return key.



A. General Information

1. Inspector:
 Robert R Kaufman
 Name of Inspector
 Butler Septic Services, LLC
 Company Name
 P.O. Box 5353
 Company Address
 Wayland MA 01778
 City/Town State Zip Code
 (508)653-7270 SI13539
 Telephone Number License Number

B. Certification

I certify that I have personally inspected the sewage disposal system at this address and that the information reported below is true, accurate and complete as of the time of the inspection. The inspection was performed based on my training and experience in the proper function and maintenance of on site sewage disposal systems. **I am a DEP approved system inspector pursuant to Section 15.340 of Title 5 (310 CMR 15.000).** The system:

- Passes Conditionally Passes Fails
 Needs Further Evaluation by the Local Approving Authority

 6/11/14
 Inspector's Signature Date

The system inspector shall submit a copy of this inspection report to the Approving Authority (Board of Health or DEP) within 30 days of completing this inspection. If the system is a shared system or has a design flow of 10,000 gpd or greater, the inspector and the system owner shall submit the report to the appropriate regional office of the DEP. The original should be sent to the system owner and copies sent to the buyer, if applicable, and the approving authority.

******This report only describes conditions at the time of inspection and under the conditions of use at that time. This inspection does not address how the system will perform in the future under the same or different conditions of use.**



Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

423 Concord Rd

Property Address

Audrey Yett

Owner's Name

Weston

City/Town

Ma

State

02493

Zip Code

6/11/14

Date of Inspection

Owner information is required for every page.

B. Certification (cont.)

Inspection Summary: Check A,B,C,D or E / **always** complete all of Section D

A) System Passes:

I have not found any information which indicates that any of the failure criteria described in 310 CMR 15.303 or in 310 CMR 15.304 exist. Any failure criteria not evaluated are indicated below.

Comments:

B) System Conditionally Passes:

One or more system components as described in the "Conditional Pass" section need to be replaced or repaired. The system, upon completion of the replacement or repair, as approved by the Board of Health, will pass.

Check the box for "yes", "no" or "not determined" (Y, N, ND) for the following statements. If "not determined," please explain.

The septic tank is metal and over 20 years old* **or** the septic tank (whether metal or not) is structurally unsound, exhibits substantial infiltration or exfiltration or tank failure is imminent. System will pass inspection if the existing tank is replaced with a complying septic tank as approved by the Board of Health.

* A metal septic tank will pass inspection if it is structurally sound, not leaking and if a Certificate of Compliance indicating that the tank is less than 20 years old is available.

Y N ND (Explain below):



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

423 Concord Rd

Property Address

Audrey Yett

Owner's Name

Weston

City/Town

Ma

State

02493

Zip Code

6/11/14

Date of Inspection

Owner information is required for every page.

B. Certification (cont.)

B) System Conditionally Passes (cont.):

Observation of sewage backup or break out or high static water level in the distribution box due to broken or obstructed pipe(s) or due to a broken, settled or uneven distribution box. System will pass inspection if (with approval of Board of Health):

broken pipe(s) are replaced Y N ND (Explain below):

obstruction is removed Y N ND (Explain below):

distribution box is leveled or replaced Y N ND (Explain below):

The system required pumping more than 4 times a year due to broken or obstructed pipe(s). The system will pass inspection if (with approval of the Board of Health):

broken pipe(s) are replaced Y N ND (Explain below):

obstruction is removed Y N ND (Explain below):

C) Further Evaluation is Required by the Board of Health:

Conditions exist which require further evaluation by the Board of Health in order to determine if the system is failing to protect public health, safety or the environment.

1. System will pass unless Board of Health determines in accordance with 310 CMR 15.303(1)(b) that the system is not functioning in a manner which will protect public health, safety and the environment:

Cesspool or privy is within 50 feet of a surface water

Cesspool or privy is within 50 feet of a bordering vegetated wetland or a salt marsh



Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

423 Concord Rd

Property Address

Audrey Yett

Owner's Name

Weston

City/Town

Ma

State

02493

Zip Code

6/11/14

Date of Inspection

Owner information is required for every page.

B. Certification (cont.)

2. System will fail unless the Board of Health (and Public Water Supplier, if any) determines that the system is functioning in a manner that protects the public health, safety and environment:

- The system has a septic tank and soil absorption system (SAS) and the SAS is within 100 feet of a surface water supply or tributary to a surface water supply.
- The system has a septic tank and SAS and the SAS is within a Zone 1 of a public water supply.
- The system has a septic tank and SAS and the SAS is within 50 feet of a private water supply well.
- The system has a septic tank and SAS and the SAS is less than 100 feet but 50 feet or more from a private water supply well**.

Method used to determine distance: _____

** This system passes if the well water analysis, performed at a DEP certified laboratory, for coliform bacteria indicates absent and the presence of ammonia nitrogen and nitrate nitrogen is equal to or less than 5 ppm, provided that no other failure criteria are triggered. A copy of the analysis must be attached to this form.

3. Other:

D) System Failure Criteria Applicable to All Systems:

You must indicate "Yes" or "No" to each of the following for all inspections:

Yes	No	
<input type="checkbox"/>	<input checked="" type="checkbox"/>	Backup of sewage into facility or system component due to overloaded or clogged SAS or cesspool
<input type="checkbox"/>	<input checked="" type="checkbox"/>	Discharge or ponding of effluent to the surface of the ground or surface waters due to an overloaded or clogged SAS or cesspool
<input type="checkbox"/>	<input checked="" type="checkbox"/>	Static liquid level in the distribution box above outlet invert due to an overloaded or clogged SAS or cesspool
<input type="checkbox"/>	<input checked="" type="checkbox"/>	Liquid depth in cesspool is less than 6" below invert or available volume is less than 1/2 day flow



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

423 Concord Rd

Property Address

Audrey Yett

Owner's Name

Weston

City/Town

Ma

State

02493

Zip Code

6/11/14

Date of Inspection

Owner information is required for every page.

B. Certification (cont.)

Yes No

Required pumping more than 4 times in the last year NOT due to clogged or obstructed pipe(s). Number of times pumped: _____.

Any portion of the SAS, cesspool or privy is below high ground water elevation.

Any portion of cesspool or privy is within 100 feet of a surface water supply or tributary to a surface water supply.

Any portion of a cesspool or privy is within a Zone 1 of a public well.

Any portion of a cesspool or privy is within 50 feet of a private water supply well.

Any portion of a cesspool or privy is less than 100 feet but greater than 50 feet from a private water supply well with no acceptable water quality analysis. [This system passes if the well water analysis, performed at a DEP certified laboratory, for fecal coliform bacteria indicates absent and the presence of ammonia nitrogen and nitrate nitrogen is equal to or less than 5 ppm, provided that no other failure criteria are triggered. A copy of the analysis and chain of custody must be attached to this form.]

The system is a cesspool serving a facility with a design flow of 2000gpd-10,000gpd.

The system fails. I have determined that one or more of the above failure criteria exist as described in 310 CMR 15.303, therefore the system fails. The system owner should contact the Board of Health to determine what will be necessary to correct the failure.

E) Large Systems: To be considered a large system the system must serve a facility with a design flow of 10,000 gpd to 15,000 gpd.

For large systems, you must indicate either "yes" or "no" to each of the following, in addition to the questions in Section D.

Yes No

the system is within 400 feet of a surface drinking water supply

the system is within 200 feet of a tributary to a surface drinking water supply

the system is located in a nitrogen sensitive area (Interim Wellhead Protection Area – IWPA) or a mapped Zone II of a public water supply well

If you have answered "yes" to any question in Section E the system is considered a significant threat, or answered "yes" in Section D above the large system has failed. The owner or operator of any large system considered a significant threat under Section E or failed under Section D shall upgrade the system in accordance with 310 CMR 15.304. The system owner should contact the appropriate regional office of the Department.



Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

423 Concord Rd

Property Address

Audrey Yett

Owner's Name

Weston

City/Town

Ma

State

02493

Zip Code

6/11/14

Date of Inspection

Owner information is required for every page.

C. Checklist

Check if the following have been done. You **must** indicate "yes" or "no" as to each of the following:

- | Yes | No | |
|-------------------------------------|-------------------------------------|--|
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Pumping information was provided by the owner, occupant, or Board of Health |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | Were any of the system components pumped out in the previous two weeks? |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Has the system received normal flows in the previous two week period? |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | Have large volumes of water been introduced to the system recently or as part of this inspection? |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Were as built plans of the system obtained and examined? (If they were not available note as N/A) |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Was the facility or dwelling inspected for signs of sewage back up? |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Was the site inspected for signs of break out? |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Were all system components, excluding the SAS, located on site? |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Were the septic tank manholes uncovered, opened, and the interior of the tank inspected for the condition of the baffles or tees, material of construction, dimensions, depth of liquid, depth of sludge and depth of scum? |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Was the facility owner (and occupants if different from owner) provided with information on the proper maintenance of subsurface sewage disposal systems? The size and location of the Soil Absorption System (SAS) on the site has been determined based on: |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Existing information. For example, a plan at the Board of Health. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Determined in the field (if any of the failure criteria related to Part C is at issue approximation of distance is unacceptable) [310 CMR 15.302(5)] |

D. System Information

Residential Flow Conditions:

Number of bedrooms (design): 5 Number of bedrooms (actual): 5

DESIGN flow based on 310 CMR 15.203 (for example: 110 gpd x # of bedrooms): _____



Commonwealth of Massachusetts
Title 5 Official Inspection Form
 Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

Owner information is required for every page.

423 Concord Rd
 Property Address
 Audrey Yett
 Owner's Name
 Weston Ma 02493 6/11/14
 City/Town State Zip Code Date of Inspection

D. System Information

Description:

Number of current residents: 3

Does residence have a garbage grinder? Yes No

Is laundry on a separate sewage system? [if **yes** separate inspection required] Yes No

Laundry system inspected? Yes No

Seasonal use? Yes No

Water meter readings, if available (last 2 years usage (gpd)): well

Detail:

Sump pump? Yes No

Last date of occupancy: _____
 Date

Commercial/Industrial Flow Conditions:

Type of Establishment: _____

Design flow (based on 310 CMR 15.203): _____
 Gallons per day (gpd)

Basis of design flow (seats/persons/sq.ft., etc.): _____

Grease trap present? Yes No

Industrial waste holding tank present? Yes No

Non-sanitary waste discharged to the Title 5 system? Yes No

Water meter readings, if available: _____



Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

423 Concord Rd

Property Address

Audrey Yett

Owner's Name

Weston

City/Town

Ma

State

02493

Zip Code

6/11/14

Date of Inspection

Owner information is required for every page.

D. System Information (cont.)

Last date of occupancy/use:

Date

Other (describe below):

General Information

Pumping Records:

Source of information:

10 months per home owner

Was system pumped as part of the inspection?

Yes No

If yes, volume pumped:

1300

gallons

How was quantity pumped determined?

measured

Reason for pumping:

inspection

Type of System:

Septic tank, distribution box, soil absorption system

Single cesspool

Overflow cesspool

Privy

Shared system (yes or no) (if yes, attach previous inspection records, if any)

Innovative/Alternative technology. Attach a copy of the current operation and maintenance contract (to be obtained from system owner) and a copy of latest inspection of the I/A system by system operator under contract

Tight tank. Attach a copy of the DEP approval.

Other (describe):



Commonwealth of Massachusetts
Title 5 Official Inspection Form
 Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

Owner information is required for every page.

423 Concord Rd
 Property Address
 Audrey Yett
 Owner's Name
 Weston Ma 02493 6/11/14
 City/Town State Zip Code Date of Inspection

D. System Information (cont.)

Approximate age of all components, date installed (if known) and source of information:

All installed 7/30/65 per as built plan

Were sewage odors detected when arriving at the site? Yes No

Building Sewer (locate on site plan):

Depth below grade: 20" feet

Material of construction:

cast iron 40 PVC other (explain):

Distance from private water supply well or suction line: 100'+ feet

Comments (on condition of joints, venting, evidence of leakage, etc.):

All appears to be ok

Septic Tank (locate on site plan):

Depth below grade: 10" for both tanks feet

Material of construction:

concrete metal fiberglass polyethylene other (explain)

If tank is metal, list age: years

Is age confirmed by a Certificate of Compliance? (attach a copy of certificate) Yes No

Dimensions: 2 @ 7.5'Lx3'Wx5'D

Sludge depth: #1 8" #2 5"



Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

423 Concord Rd

Property Address

Audrey Yett

Owner's Name

Weston

City/Town

Ma

State

02493

Zip Code

6/11/14

Date of Inspection

Owner information is required for every page.

D. System Information (cont.)

Septic Tank (cont.)

Distance from top of sludge to bottom of outlet tee or baffle

#1 22" #2 25"

Scum thickness

#1 2" #2 skim

Distance from top of scum to top of outlet tee or baffle

#1 6" #2 6"

Distance from bottom of scum to bottom of outlet tee or baffle

#1 16" #2 18"

How were dimensions determined?

Tape measure

Comments (on-pumping recommendations, inlet and outlet tee or baffle condition, structural integrity, liquid levels as related to outlet invert, evidence of leakage, etc.):

2 septic tanks connected in series. Outlet tee's for both tanks are intact and ok. Liquid level is 4'. Some deterioration @ water line in tank #2 but ok. Both septic tanks should be pumped yearly for proper maintenance.

Grease Trap (locate on site plan):

Depth below grade:

feet

Material of construction:

concrete

metal

fiberglass

polyethylene

other (explain):

Dimensions:


Scum thickness

Distance from top of scum to top of outlet tee or baffle

Distance from bottom of scum to bottom of outlet tee or baffle

Date of last pumping:

Date



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

423 Concord Rd

Property Address

Audrey Yett

Owner's Name

Weston

Ma
State

02493
Zip Code

6/11/14

Date of Inspection

Owner information is required for every page.

D. System Information (cont.)

Comments (on pumping recommendations, inlet and outlet tee or baffle condition, structural integrity, liquid levels as related to outlet invert, evidence of leakage, etc.):

Empty lines for comments.

Tight or Holding Tank (tank must be pumped at time of inspection) (locate on site plan):

Depth below grade: _____

Material of construction:

concrete metal fiberglass polyethylene other (explain):

Dimensions: _____

Capacity: _____

gallons

Design Flow: _____

gallons per day

Alarm present: _____

Yes No

Alarm level: _____

Alarm in working order: Yes No

Date of last pumping: _____

Date

Comments (condition of alarm and float switches, etc.):

Empty lines for comments.

* Attach copy of current pumping contract (required). Is copy attached? Yes No



Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

423 Concord Rd

Property Address

Audrey Yett

Owner's Name

Weston

City/Town

Ma

State

02493

Zip Code

6/11/14

Date of Inspection

Owner information is required for every page.

D. System Information (cont.)

Distribution Box (if present must be opened) (locate on site plan):

Depth of liquid level above outlet invert 0"

Comments (note if box is level and distribution to outlets equal, any evidence of solids carryover, any evidence of leakage into or out of box, etc.):

24"x16" D-box 25" below grade with 4 pipes exiting. Box is showing signs of deterioration but ok. Small amount of solids carryover. All exit pipes are equal with flow.

Pump Chamber (locate on site plan):

Pumps in working order: Yes No

Alarms in working order: Yes No

Comments (note condition of pump chamber, condition of pumps and appurtenances, etc.):

Soil Absorption System (SAS) (locate on site plan, excavation not required):

If SAS not located, explain why:



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

423 Concord Rd

Property Address

Audrey Yett

Owner's Name

Weston

City/Town

Ma

State

02493

Zip Code

6/11/14

Date of Inspection

Owner information is required for every page.

D. System Information (cont.)

Type:

- leaching pits number: _____
- leaching chambers number: _____
- leaching galleries number: _____
- leaching trenches number, length: 4 @ 44'
- leaching fields number, dimensions: _____
- overflow cesspool number: _____
- innovative/alternative system

Type/name of technology: _____

Comments (note condition of soil, signs of hydraulic failure, level of ponding, damp soil, condition of vegetation, etc.):

4 - 44' trenches in stone. All trenches are taking liquid @ full flow and working ok. Soil is medium gravel with vegetation being lawn and normal. Property slopes away from leaching.

Cesspools (cesspool must be pumped as part of inspection) (locate on site plan):

Number and configuration _____

Depth – top of liquid to inlet invert _____


Depth of solids layer _____

Depth of scum layer _____

Dimensions of cesspool _____

Materials of construction _____

Indication of groundwater inflow Yes No



Commonwealth of Massachusetts
Title 5 Official Inspection Form
 Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

423 Concord Rd
 Property Address
 Audrey Yett
 Owner's Name
 Weston Ma 02493 6/11/14
 City/Town State Zip Code Date of Inspection

Owner information is required for every page.

D. System Information (cont.)

Sketch Of Sewage Disposal System: Provide a view of the sewage disposal system, including ties to at least two permanent reference landmarks or benchmarks. Locate all wells within 100 feet. Locate where public water supply enters the building. Check one of the boxes below:

- hand-sketch in the area below
- drawing attached separately

Date of inspection: 4/30/09

SKETCH OF SEWAGE DISPOSAL SYSTEM:
 include ties to at least two permanent reference landmarks or benchmarks
 locate all wells within 100' (Locate where public water supply comes into house)

	A	B	C
# 1		21' 9"	42' 9"
# 2		28' 2"	50' 6"
# 3	76' 7"	89' 2"	

4 - 44' Leaching trenches



Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

423 Concord Rd

Property Address

Audrey Yett

Owner's Name

Weston

City/Town

Ma

State

02493

Zip Code

6/11/14

Date of Inspection

Owner information is required for every page.

D. System Information (cont.)

Site Exam:

Check Slope

Surface water

Check cellar

Shallow wells

Estimated depth to high ground water:

6'

feet

Please indicate all methods used to determine the high ground water elevation:

Obtained from system design plans on record

If checked, date of design plan reviewed:

Date

Observed site (abutting property/observation hole within 150 feet of SAS)

Checked with local Board of Health - explain:

Obtained from previous inspection on file

Checked with local excavators, installers - (attach documentation)

Accessed USGS database - explain:

You **must** describe how you established the high ground water elevation:

Observed site.

Before filing this Inspection Report, please see Report Completeness Checklist on next page.



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

423 Concord Rd

Property Address

Audrey Yett

Owner's Name

Weston

Ma

02493

6/11/14

City/Town

State

Zip Code

Date of Inspection

Owner information is required for every page.

E. Report Completeness Checklist

- Inspection Summary: A, B, C, D, or E checked
- Inspection Summary D (System Failure Criteria Applicable to All Systems) completed
- System Information – Estimated depth to high groundwater
- Sketch of Sewage Disposal System either drawn on page 15 or attached in separate file